



## AJZV.R5628 Filter Units, Air

[Page Bottom](#)

---

### Filter Units, Air

[See General Information for Filter Units, Air](#)

#### **SUPERIOR FIBERS INC**

R5628

Rt 92 South PO Box 478  
Reedsville, WV 26547 USA

**Replaceable, dry-type or adhesive coated roll media**, "Superior Glass""Superior Fibers" or "84WRM05" , maximum thickness of 5 in., (max weight 70 g/sq ft), Class 2.

**Dry-type replaceable media**, "Dry Industrial Media", maximum 2 in. thick, Class 1.

**Dry-type or adhesive coated, replaceable air fliter media**, "TotalTac" or "Superior", max thickness of 5 in., (max weight 70 g/sq ft), Class 2.

**Replaceable, dry-type roll media and replaceable, adhesive coated roll media**, designated as "Air Filter Unit", 4 in. maximum thickness, Class 2.

**Replaceable, dry-type roll media and replaceable, adhesive coated roll media**, designated "Prebond" or "PB", 4 in. maximum thickness, Class 2.

**Throw-away, dry-type air filter pads**, designated "Pyro-Guard" or "PG", 2 1/2 in. maximum thickness, Class 1.

**Replaceable, dry-type roll media**, designated P MEC, PMC, PME, PM, PMN, P MECT, PMCT, PMET, PMT, PMNT, P MEC#BS, PMC#BS, PME#BS, PM#BS, PMN#BS, RKWH# 1/16 in. maximum thickness, Class 1.

[Last Updated](#) on 2009-09-10

---

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2010 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

